

OR 7398
1-30-84
4C



CITY OF

PORTLAND, OREGON

BUREAU OF ENVIRONMENTAL SERVICES

Mike Lindberg, Commissioner
John Lang, Administrator
1120 S.W. 5th Ave.
Portland, Oregon 97204-1972
(503) 796-7169

January 30, 1984

Certified Mail
Return Receipt Requested

NOTICE OF VIOLATION

Van Waters & Rogers
3950 N.W. Yeon Avenue
Portland, OR 97210

Attention: Mr. Stan West, Area Operations Manager

Dear Mr. West:

This will document and follow-up on last Friday's (1-27-84) telephone call from Jim McCadden notifying you of the serious Code violation of the previous day. Specifically, the grab sample of your effluent to the City sewer as analyzed at our laboratory exhibited a pH of 0.8. This is a gross violation of section 17.34.030 (b6) of the City Code. More importantly, it points up the urgent need to implement the following pollution control measures discussed earlier and required by Code.

Action	By (date)	Code Cite
1. Apply for an industrial waste discharge permit	02/10/84	17.34.070
2. Submit an approvable SPCC plan	03/01/84	17.34.090
3. Operate and maintain all pretreatment equipment in a manner to ensure that all future discharges comply with the limits specified under the authority of Portland's Industrial Wastewater Regulations	Immediately	Chapter 17.34 of City Code

Your cooperation in this matter will eliminate the need to proceed with more drastic enforcement measures and will be sincerely appreciated. If you have any questions, please give me a call at 796-7125.

Yours very truly,

Harry G. Edmonds
Industrial Waste Engineer

Enclosure

HGE/rlm

cc: John Lang
Joe Niehuser
Jim Cooke

Engineering
Bill Gaffi
796, 7181

System Management
Joe Niehuser
796, 7128

Wastewater Treatment
Jack Irvin
285 0,205

Solid Waste
Delyn Kies
796, 7010

USEPA RCRA



3021020

FILE COPY